



REF. TO: STANDARD TANK
DATE: 05/20/08

DWG BY: JR

TITLE: **ABDW-275-12P**

SCALE: 1:16

LEGEND: ID - (QTY. OF OPENINGS) PART

- A - (3) 2" FNPT FLANGE
- B - (1) 3' OUTER EVENT FLANGE
- C - (1) 3' INNER EVENT FLANGE
- D - (1) FORGED LIFT LUG
- E - (4) LEG LUG
- F - (1) INSPECTION PIPE

DESCRIPTION:

ABOVE GROUND, DOUBLE WALL
12 GA INNER, 12 GA OUTER
STEEL STORAGE TANK
268 GALLONS
CAPACITY:

FINISH:
SURFACE PREP: SPCC SP-3; ONE
SPRAY COAT OF PRIMER; OPT FINISH

SIGNED APPROVAL:



Underwriters
Laboratories Inc.
LISTED



1500 HWY 117 S.
GOLDSBORO, NC 27530
P: (919) 734-8328
F: (919) 736-4550