



REF. TO: STANDARD TANK  
 DATE: 05/20/08  
 DWG BY: AH

TITLE: **AHDW-1000/46-10P**  
 SCALE: 1:28

LEGEND: ID - (QTY. OF OPENINGS) PART

- A - (4) 2" NPT CPL
- B - (1) 6" INNER EVENT CPL
- C - (1) 6" OUTER EVENT FLANGE
- D - (1) 2" INSPECTION PIPE
- E - (1) FORGED LIFT LUG

DESCRIPTION: ABOVE GROUND, DOUBLE WALL 10 GA. INNER/12 GA. OUTER STEEL STORAGE TANK  
 CAPACITY: 1002 GALLONS  
 FINISH: SURFACE PREP. SPCC SP-3; ONE SPRAY COAT OF PRIMER; OPT FINISH  
 APPROX. WEIGHT: 1928 lbs ± 5%

TURNER TANKS  
 1500 HWY 117 S.  
 GOLDSBORO, NC 27530  
 P: (919) 734-8328  
 F: (919) 736-4550  
 SIGNED APPROVAL:

