



REF. TO: STANDARD TANK  
DATE: 05/20/08

DWG BY: AH

TITLE: **AHDW-1000/64-10P**

SCALE: 1:32

LEGEND: ID - (QTY. OF OPENINGS) PART

- A - (4) 2" NPT CPL
- B - (1) 6" INNER EVENT CPL
- C - (1) 6" OUTER EVENT FLANGE
- D - (1) 2" INSPECTION PIPE
- E - (1) FORGED LIFT LUG

DESCRIPTION:

ABOVE GROUND, DOUBLE WALL  
10 GA. INNER/1/2 GA. OUTER  
STEEL STORAGE TANK  
979 GALLONS

FINISH:  
SURFACE PREP: SPCC SP-3; ONE  
SPRAY COAT OF PRIMER; OPT FINISH  
APPRX. WEIGHT: 1676 lbs ± 5%

CAPACITY:

1500 HWY 117 S.  
GOLDSBORO, NC 27530  
P: (919) 734-8328  
F: (919) 736-4550

SIGNED APPROVAL:



Underwriters  
Laboratories Inc.  
LISTED