



REF. TO: STANDARD TANK
DATE: 05/20/08

DWG BY: AH

TITLE: **AHDW-1500-7P**

SCALE: 1:32

LEGEND: ID - (QTY. OF OPENINGS) PART

- A - (3) 2" NPT CPL
- B - (1) 6" INNER EVENT CPL
- C - (1) 6" OUTER EVENT FLANGE
- D - (1) 4" NPT CPL
- E - (1) 2" INSPECTION PIPE
- F - (2) FORGED LIFT LUG

DESCRIPTION: ABOVE GROUND, DOUBLE WALL
7 GA. INNER/10 GA. OUTER
STEEL STORAGE TANK
CAPACITY: 1469 GALLONS

FINISH: SURFACE PREP. SPCC SP-3; ONE
SPRAY COAT OF PRIMER; OPT FINISH
APPRX. WEIGHT: 2935 lbs ± 5%

1500 HWY 117 S.
GOLDSBORO, NC 27530
P: (919) 734-8328
F: (919) 736-4550

SIGNED APPROVAL:



Underwriters
Laboratories Inc.
LISTED