



REF. TO: STANDARD TANK DATE: 04/24/09 DWG BY: JR	TITLE: AHDW-4000/64-7P SCALE: 1:48	DESCRIPTION: ABOVE GROUND, DOUBLE WALL 7 GA. INNER/10 GA. OUTER STEEL STORAGE TANK CAPACITY: 3917 GALLONS	FINISH: SURFACE PREP: SPCC SP-3; ONE SPRAY COAT OF PRIMER; OPT FINISH APPROX. WEIGHT: 6638 lbs ± 5%
 Underwriters Laboratories Inc. <small>LISTED ®</small>	LEGEND: ID - (QTY. OF OPENINGS) PART A - (4) 2' NPT CPL D - (1) 4' NPT CPL B - (1) 8' INNER E.VENT CPL E - (1) 2' INSPECTION PIPE C - (1) 8' OUTER E.VENT FLANGE F - (2) FORGED LIFT LUG	 1500 HWY 117 S. GOLDSBORO, NC 27530 P: (919) 734 - 8328 F: (919) 736 - 4550	SIGNED APPROVAL: