



REF. TO: STANDARD TANK
DATE: 05/20/08

DWG BY: AH

TITLE:

AHDW-525-12P

SCALE: 1:20

LEGEND: ID - (QTY. OF OPENINGS) PART

- A - (4) 2" NPT CPL
- B - (1) 4" INNER EVENT CPL
- C - (1) 4" OUTER EVENT FLANGE
- D - (1) 2" INSPECTION PIPE
- E - (1) FORGED LIFT LUG

DESCRIPTION:

ABOVE GROUND, DOUBLE WALL
12 GA. INNER/12 GA. OUTER
STEEL STORAGE TANK
508 GALLONS

FINISH:
SURFACE PREP: SPCC SP-3; ONE
SPRAY COAT OF PRIMER; OPT FINISH
APPRX. WEIGHT: 890 lbs ± 5%

CAPACITY:

1500 HWY 117 S.

GOLDSBORO, NC 27530

P: (919) 734 - 8328

F: (919) 736 - 4550

SIGNED APPROVAL:



Underwriters
Laboratories Inc.
LISTED

