



\*Typical  $\frac{1}{8}$ " thick pad,  
fully sealed weld between tank and  
saddle.

\*Saddle Dim:

\*Pad Dim:

REF. TO: STANDARD TANK  
DATE: 05/20/08

DWG BY: AH

TITLE:

**AS-1000/46-10P**

SCALE: 1:48

LEGEND: ID - (QTY. OF OPENINGS) PART

- A - (4) 2" FNPT FLANGE
- B - (1) 6" EVENT FLANGE
- C - (1)  $\frac{3}{4}$ " FNPT FLANGE
- D - (2) LIFTING LUG

DESCRIPTION:

ABOVE GROUND, SINGLE WALL  
10 GA. STEEL STORAGE TANK  
CAPACITY: 1036 GALLONS

FINISH:

SURFACE PREP: SPCC SP-3; ONE  
SPRAY COAT OF PRIMER; OPT FINISH  
APPROX. WEIGHT: 975 lbs  $\pm$  5%

SIGNED APPROVAL:



Underwriters  
Laboratories Inc.  
LISTED



1500 HWY 117 S.  
GOLDSBORO, NC 27530  
P: (919) 734-8828  
F: (919) 736-4650