



DESCRIPTION:	ABOVE GROUND DOUBLE WALL, STEEL STORAGE TANK, 2000 GALLONS
MATERIAL:	7 GA. INNER/10 GA. OUTER
CONSTRUCTION:	WELDED USING UL-142 STANDARDS
OPENINGS:	4-4" CPL. 1-6" INNER EVENT CPL. 1-6" OUTER EVENT FLANGE
FINISH:	SURFACE PREP. SPEC. SP-3 ONE SPRAY COAT OF RED PRIMER

REF. TO:	
DATE:	
TITLE:	ASDW-2000-7

TURNER TANKS;
GOLDSBORO, NC
(919) 734 - 8328

SIZE:	A
LEGEND:	A - 4" COUPLING B - 6" INNER EVENT CPL. C - 6" OUTER EVENT FLANGE D - 2" INSPECTION PIPE E - FORKED LIFT LUG
SCALE:	1:48
APPROVAL:	