



DESCRIPTION:	ABOVE GROUND, DOUBLE WALL, STEEL STORAGE TANK, 3000 GALLONS
MATERIAL:	7 GA. INNER/10 GA. OUTER
CONSTRUCTION:	WELDED USING UL-142 STANDARDS
OPENINGS:	4-2" CHL 1-4" CHL 1-6" INNER EVENT CHL 1-6" OUTER EVENT FLANGE
FINISH:	SURFACE PREP: SPCC SP-3 DNE SPRAY COAT OF RED PRIMER

TURNER TANKS:
GOLDSBORO, NC
(919) 734 - 8328

REF. ID:	
DATE:	
TITLE:	ASDW-3000-7P
SIZE:	A
LEGEND:	A - 2" FLANGE B - 6" INNER EVENT CHL C - 6" OUTER EVENT FLANGE D - EXTRA 4" CHL E - 2" INSPECTION PRT F - FORCED LIFT LUG
SCALE:	1:64
APPROVAL:	