


REF. TO: STANDARD TANK  
DATE: 05/20/08  
DWG BY: AH

TITLE:  
**AUDW-330-12P**  
SCALE: 1:24

DESCRIPTION:  
ABOVE GROUND, DOUBLE WALL  
12 GA. INNER/12 GA. OUTER  
STEEL STORAGE TANK  
CAPACITY:  
322 GALLONS  
FINISH:  
SURFACE PREP: SPCC SP-3; ONE  
SPRAY COAT OF PRIMER; OPT FINISH  
APPROX. WEIGHT: 650 lbs ± 5%

  
Underwriters  
Laboratories Inc.  
LISTED ®

LEGEND: ID - (QTY. OF OPENINGS) PART  
A - (4) 2" NPT CPL  
B - (1) 3" INNER EVENT CPL  
C - (1) 3" OUTER EVENT FLANGE  
D - (1) 2" INSPECTION PIPE  
E - (1) LIFTING LUG

  
**TURNER  
TANKS**  
1500 HWY 117 S.  
GOLDSBORO, NC 27530  
P: (919) 734-8828  
F: (919) 736-4650  
SIGNED APPROVAL: