




SPECIFICATIONS & CONSTRUCTION INFORMATION

MODEL: AUDW-525-12B  
 DESCRIPTION: ABOVEGROUND, DOUBLE WALL STEEL STORAGE TANK  
 CONSTRUCTION: WELDED USING UL-142 STANDARDS  
 FINISH: SURFACE PREP, SPOC SP-3  
 ONE SPRAY COAT OF RED PRIMER  
 FINISH ENAMEL COAT IS OPTIONAL

INNER TANK: 12 GAUGE  
 OUTER TANK: 12 GAUGE  
 OPENINGS: MINIMUM 3-2" FNPT COUPLINGS  
 1-4" FNPT COUPLING  
 1-4" FNPT FLANGE



FINISH COLOR CASTROL GREEN



LEGEND

- A - OPENINGS FOR FILL, GAUGE, AND NORMAL VENT: 2" FNPT COUPLING
- B - OPENING FOR INNER TANK EMER. VENT 4" COUPLING
- C - OPENING FOR OUTER TANK EMER. VENT 4" FLANGE
- D - INTERSTICE INSPECTION TUBE
- E - LIFT LUG
- F - TURNER REEL MOUNTING PLATE

DWG # AUDW-525-12B

SCALE: NONE

DATE: 11/16/05

REVISION:

APPROVED:

APPROVAL DATE: