



REF. TO: STANDARD TANK  
DATE: 08/21/09

DWG BY: JR

TITLE:

**LCW-1000-10P**

SCALE: 1:16

LEGEND: ID - (QTY, OF OPENINGS) PART

A - (4) 2" FNPT FLANGE

C - (1) 1-1/2" FNPT FLANGE

B - (1) 6" EVENT FLANGE

DESCRIPTION:

ABOVE GROUND, SINGLE WALL  
10 GA. STEEL STORAGE TANK.

CAPACITY:

1017 GALLONS

FINISH:

SURFACE PREP: SPCC SP-3; ONE  
SPRAY COAT OF RED PRIMER  
APPROX. WEIGHT: 1210 LBS.

SIGNED APPROVAL:



Underwriters  
Laboratories Inc.  
LISTED



1500 HWY 117 S.  
GOLDSBORO, NC 27530  
P: (919) 734 - 8328  
F: (919) 736 - 4550