

REF. TO: STANDARD TANK DATE: 05/20/08 DWG BY: AH

TITLE: LV-1000-10P

DESCRIPTION:

CAPACITY:

SCALE: 1:24

ABOVE GROUND, SINGLE WALL 10 GA. STEEL STORAGE TANK

1,003 GALLONS

FINISH:
SURFACE PREP: SPCC SP-3; DNE
SPRAY COAT OF PRIMER; OPT FINISH APPROX. WEIGHT: 877 lbs ± 5%

Underwriters Laboratories Inc.

LEGEND: ID - (QTY. DF DPENINGS) PART A - (4) 2" FNPT FLANGE

C - (1) 1 ½" FNPT FLANGE

D - (1) FORMED LIFT LUG B - (1) 6" E.VENT FLANGE

E - (2) FORGED LIFT LUG

1500 HWY 117 S. GOLDSBORO, NC 27530 P: (919) 734 - 8328 F: (919) 736 - 4550

SIGNED APPROVAL: