

REF. TO: STANDARD TANK DATE: 05/20/08

DWG BY: AH

TITLE: LV-525-12P

SCALE: 1:24

LEGEND: ID - (QTY. DF DPENINGS) PART

A - (4) 2" FNPT FLANGE B - (1) 4" E.VENT FLANGE C - (1) 3/4" FNPT FLANGE D - (1) LIFTING LUG

DESCRIPTION:

CAPACITY:

ABOVE GROUND, SINGLE WALL 12 GA. STEEL STORAGE TANK

518 GALLONS

FINISH:
SURFACE PREP: SPCC SP-3; DNE
SPRAY COAT OF PRIMER; OPT FINISH

APPROX. WEIGHT: 570 lbs ± 5% SIGNED APPROVAL:

P: (919) 734 - 8328 F: (919) 736 - 4550

Underwriters Laboratories Inc. 1500 HWY 117 S. GOLDSBORO, NC 27530