



Underwriters
Laboratories Inc.
LISTED ®

REF. TO: STANDARD TANK
DATE: 05/20/08

DWG BY: AH

TITLE:

LV-525-12P

SCALE: 1:24

LEGEND: ID - (QTY, OF OPENINGS) PART

- A - (4) 2" FNPT FLANGE
- B - (1) 4" EVENT FLANGE
- C - (1) 3/4" FNPT FLANGE
- D - (1) LIFTING LUG

DESCRIPTION:

ABOVE GROUND, SINGLE WALL
12 GA. STEEL STORAGE TANK
CAPACITY: 518 GALLONS

FINISH:
SURFACE PREP: SPCC, SP-3; ONE
SPRAY COAT OF PRIMER; OPT FINISH
APPROX. WEIGHT: 570 lbs ± 5%



1500 HWY 117 S,
GOLDSBORO, NC 27530
P: (919) 734-8828
F: (919) 736-4650

SIGNED APPROVAL:

