

 Ω

 Ω

 \geq (/) ANK α TURNE

QUAN. STOCK # DESCRIPTION SPECIFICATIONS & CONSTRUCTION INFORMATION OUAN. STOCK # DESCRIPTION

MDDEL LVDW-270-12

DESCRIPTION ABDVEGROUND, DOUBLE WALL OBROUND STEEL STORAGE TANK INNER TANK: 12 GAUGE

OUTER TANK: 12 GAUGE

OPENINGS: MINIMUM 4-2* FNPT FLANGES

1-3* FNPT FLANGE

1-3* FNPT FLANGE


1-3* FNPT ELBOW W/CAP

1-2* INSPECTION COUPLING WITH STEEL CAP


CONSTRUCTION VELDED USING UL-142 STANDARDS

FINISH: SURFACE PREP: SSPC SP-3

FINISH: RED PRIMER NOTE: FINISH ENAMEL COAT IS OPTIONAL



Ø36" INNER



LEGEND

A - DPENINGS FOR FILL, GAUGE, AND NORMAL VENT: 2" FNPT COUPLING B - DPENINGS FOR INNER TANK EMERGENCY VENT: 3" FNPT FLANGE

C - DPENING FOR DUTER TANK EMERGENCY VENT: 3" FNPT PIPE ELBOW WITH CAP

D - 3/4" FNPT WITH STEEL CAP

DWG #: LVDW-270-12 SCALE: NONE DATE: 06/25/07 REVISION: APPROVED: APPROVAL DATE: