



FORMED CHANNEL

REF. TO: STANDARD TANK
DATE: 05/20/08

DWG BY: AH

TITLE:

PLT-1000-10P

SCALE: 1:32

LEGEND: ID - (QTY. OF OPENINGS) PART

A - (4) 2" FNPT FLANGE
B - (1) 6" EVENT FLANGE
C - (1) 1 1/2" FNPT FLANGE
D - (2) LIFTING LUG

DESCRIPTION:

ABOVE GROUND, SINGLE WALL
10 GA. STEEL LUBE RECT.
STORAGE TANK
997 GALLONS

FINISH:
SURFACE PREP, SPCC, SP-3; ONE
SPRAY COAT OF PRIMER; OPT FINISH
APPROX. WEIGHT: 1,060 lbs ± 5%

CAPACITY:

1500 HWY 117 S.

GOLDSBORO, NC 27530

P: (919) 734 - 8328

F: (919) 736 - 4650

SIGNED APPROVAL:



Underwriters
Laboratories Inc.
LISTED



TURNER
TANKS