



FORMED CHANNEL

REF. TO: STANDARD TANK
DATE: 05/20/08
DWG BY: AH

TITLE: **PLT-1500-7P**

SCALE: 1:48

DESCRIPTION:

ABOVE GROUND, SINGLE WALL
7 GA. STEEL LUBE RECT.
STORAGE TANK
1,589 GALLONS

FINISH:
SURFACE PREP: SPCC, SP-3; ONE
SPRAY COAT OF PRIMER; OPT FINISH
APPROX. WEIGHT: 1,200 lbs ± 5%

LEGEND: ID - (QTY. OF OPENINGS) PART

A - (4) 2' FNPT FLANGE
B - (1) 6' EVENT FLANGE
C - (1) 1 1/2' FNPT FLANGE
D - (2) LIFTING LUG



Underwriters
Laboratories Inc.
LISTED



1500 HWY 117 S.
GOLDSBORO, NC 27530
P: (919) 734 - 8328
F: (919) 736 - 4550

SIGNED APPROVAL: