



FORMED CHANNEL

REF. TO: STANDARD TANK
DATE: 07/17/09

DWG BY: JR

TITLE:

PLT-2000-7P

LEGEND: ID - (QTY. OF OPENINGS) PART

SCALE: 1:48

A - (4) 2" FNPT FLANGE
B - (1) 6" EVENT FLANGE
C - (1) 1 1/2" FNPT FLANGE
D - (2) LIFTING LUG

DESCRIPTION:

ABOVE GROUND, SINGLE WALL
7 GA. STEEL LUBE RECT.
STORAGE TANK
2040 GALLONS

FINISH:
SURFACE PREP: SPCC SP-3; DNE
SPRAY COAT OF PRIMER; DPT FINISH
APPROX. WEIGHT:

SIGNED APPROVAL:



Underwriters
Laboratories Inc.
LISTED



1500 HWY 117 S.
GOLDSBORO, NC 27530
P: (919) 734-8328
F: (919) 736-4550