



REF. TO: STANDARD TANK  
DATE: 07/17/09

DWG BY: JR

TITLE: **PLT-2000-7P**

SCALE: 1:48

DESCRIPTION: ABOVE GROUND, SINGLE WALL  
7 GA. STEEL LUBE RECT.  
STORAGE TANK  
CAPACITY: 2040 GALLONS

FINISH: SURFACE PREP: SPCC SP-3; ONE  
SPRAY COAT OF PRIMER; OPT FINISH  
APPROX. WEIGHT:



Underwriters  
Laboratories Inc.  
LISTED

LEGEND: ID - (QTY. OF OPENINGS) PART

A - (4) 2" FNPT FLANGE      C - (1) 1 1/2" FNPT FLANGE  
B - (1) 6" E.VENT FLANGE    D - (2) LIFTING LUG



1500 HWY 117 S.  
GOLDSBORO, NC 27530  
P: (919) 734 - 8328  
F: (919) 736 - 4550

SIGNED APPROVAL: