



REF. TO: STANDARD TANK
DATE: 05/28/08

DWG BY: AH

TITLE:

PLTDW-2000-7P

SCALE: 1:48

LEGEND: ID - (QTY, OF OPENINGS) PART

A - (5) 2' FNPT FLANGE
B - (1) 6' INNER EVENT CPL
C - (1) 6' OUTER EVENT FLANGE
D - (2) FORGED LIFT LUG

DESCRIPTION:

ABOVE GROUND, DOUBLE WALL
7 GA. INNER/10 GA. OUTER
PIT LUBE, STEEL STORAGE TANK
2,015 GALLONS

FINISH:
SURFACE PREP: SPCC SP-3; ONE
SPRAY COAT OF RED PRIMER
APPROX. WEIGHT: 2,890 lbs ± 5%

CAPACITY:

1500 HWY 117 S,
GOLDSBORO, NC 27530

SIGNED APPROVAL:



Underwriters
Laboratories Inc.
LISTED



1500 HWY 117 S,
GOLDSBORO, NC 27530
P: (919) 734 - 8328
F: (919) 736 - 4550