



REF. TO: STANDARD TANK
DATE: 05/20/08

DWG BY: AH

TITLE: **PLTDW-750-10P**

SCALE: 1:24

DESCRIPTION: ABOVE GROUND, DOUBLE WALL
10 GA. INNER/12 GA. OUTER
STEEL PIT LUBE STORAGE TANK
CAPACITY: 748 GALLONS

FINISH: SURFACE PREP: SPCC SP-3; ONE
SPRAY COAT OF PRIMER; OPT FINISH
APPROX. WEIGHT: 1,315 lbs ± 5%



Underwriters
Laboratories Inc.
LISTED ®

LEGEND: ID - (QTY. OF OPENINGS) PART

A - (5) 2" FNPT FLANGE
B - (1) 6" INNER E.VENT FLANGE
C - (1) 6" OUTER E.VENT FLANGE
D - (2) FORGED LIFTING LUG



1500 HWY 117 S.
GOLDSBORO, NC 27530
P: (919) 734 - 8328
F: (919) 736 - 4550

SIGNED APPROVAL: