



REF. TO: STANDARD TANK
DATE: 05/20/08

DWG BY: AH

TITLE:

ST-150-12P

SCALE: 1:12

LEGEND: ID - (QTY, OF OPENINGS) PART

- A - (4) 2" FNPT FLANGE
- B - (1) 3" E.VENT FLANGE
- C - (1) 3/4" FNPT FLANGE
- D - (1) LIFTING LUG

DESCRIPTION:

ABOVE GROUND, SINGLE WALL
12 GA. STEEL STORAGE TANK
DN SKIDS
153 GALLONS

FINISH:
SURFACE PREP: SPCC SP-3; ONE
SPRAY COAT OF PRIMER; OPT FINISH
APPROX. WEIGHT: 232 lbs ± 5%

CAPACITY:

1500 HWY 117 S.

GOLDSBORO, NC 27530

P: (919) 734 - 8328

F: (919) 736 - 4550

SIGNED APPROVAL:



Underwriters
Laboratories Inc.
LISTED

