



REF. TO: STANDARD TANK
 DATE: 05/20/08
 DWG BY: JR

TITLE: **ABDW-275-12P**
 SCALE: 1:16

DESCRIPTION: ABOVE GROUND, DOUBLE WALL
 12 GA INNER, 12 GA. OUTER.
 CAPACITY: STEEL STORAGE TANK
 268 GALLONS

FINISH: SURFACE PREP: SPCC SP-3; ONE
 SPRAY COAT OF PRIMER; OPT FINISH



LEGEND: ID - (QTY. OF OPENINGS) PART
 A - (3) 2" FNPT FLANGE D - (1) FORGED LIFT LUG
 B - (1) 3" OUTER E.VENT FLANGE E - (4) LEG LUG
 C - (1) 3" INNER E.VENT FLANGE F - (1) INSPECTION PIPE

TURNER TANKS
 1500 HWY 117 S.
 GOLDSBORO, NC 27530
 P: (919) 734 - 8328
 F: (919) 736 - 4550

SIGNED APPROVAL: