



DESCRIPTION:	ABOVE GROUND, DOUBLE WALL, STEEL STORAGE TANK 991 GALLONS	REF. TO: GENERAL INDUSTRIES
MATERIAL:	10 GA. INNER/12 GA. OUTER	DATE: 04/29/08
CONSTRUCTION:	WELDED USING UL-142 STANDARDS	TITLE:
OPENINGS:	3-2" CPLS 1-6" INNER EVENT CPL 1-6" OUTER EVENT FLANGE	ASDW 1000/46-10P
FINISH:	SURFACE PREP: SPCC SP-3 ONE SPRAY COAT OF RED PRIMER	SIZE: A
TURNER TANKS: GOLDSBORO, NC (919) 734 - 8328		LEGEND:
		SCALE: 1:48
		D - 2" INSPECTION PIPE E - FORGED LIFT LUG
		APPROVAL: