



DESCRIPTION:	ABOVE GROUND, DOUBLE WALL, STEEL STORAGE TANK 1500 GALLONS	REF. TO:	
MATERIAL:	7 GA. INNER/10 GA. OUTER	DATE:	
CONSTRUCTION:	WELDED USING UL-142 STANDARDS	TITLE:	ASDW-1500-7P
OPENINGS:	3-2" CPL 1-4" CPL 1-6" INNER EVENT CPL 1-6" OUTER EVENT FLANGE	SIZE	LEGEND:
FINISH:	SURFACE PREP: SPCC SP-3 ONE SPRAY COAT OF RED PRIMER	A	A - 2" FLANGE B - 6" INNER EVENT CPL C - 6" OUTER EVENT FLANGE
TURNER TANKS: GOLDSBORO, NC (919) 734 - 8328		SCALE: 1:28	APPROVAL:
			D - EXTRA 4" CPL E - 2" INSPECTION PIPE F - FORGED LIFT LUG