



DESCRIPTION:	ABOVE GROUND, DOUBLE WALL, STEEL STORAGE TANK 2000 GALLONS	REF. TO:	
MATERIAL:	7 GA. INNER/10 GA. OUTER	DATE:	
CONSTRUCTION:	WELDED USING UL-142 STANDARDS	TITLE:	ASDW-2000-7
OPENINGS:	4-4" CPL 1-6" INNER EVENT CPL 1-6" OUTER EVENT FLANGE	SIZE:	A
FINISH:	SURFACE PREP: SPCC SP-3 ONE SPRAY COAT OF RED PRIMER	LEGEND:	A - 4" COUPLING B - 6" INNER EVENT CPL C - 6" OUTER EVENT FLANGE D - 2" INSPECTION PIPE E - FORGED LIFT LUG
TURNER TANKS: GOLDSBORO, NC (919) 734 - 8328		SCALE: 1:48	APPROVAL: