



DESCRIPTION:	ABOVE GROUND, DOUBLE WALL, STEEL STORAGE TANK 525 GALLONS	REF. TO:	
MATERIAL:	12 GA. INNER/12 GA. OUTER	DATE:	
CONSTRUCTION:	WELDED USING UL-142 STANDARDS	TITLE:	ASDW-525-12P
OPENINGS:	4-2" CPL 1-4" INNER E.VENT CPL 1-4" OUTER E.VENT FLANGE	SIZE	LEGEND:
FINISH:	SURFACE PREP: SPCC SP-3 ONE SPRAY COAT OF RED PRIMER	A	A - 2" CPL B - 4" INNER E.VENT CPL C - 4" OUTER E.VENT FLANGE
TURNER TANKS: GOLDSBORO, NC (919) 734 - 8328		D	D - 2" INSPECTION PIPE E - FORGED LIFT LUG
		SCALE: 1:20	APPROVAL: