



REF. TO: STANDARD TANK  
DATE: 05/20/08

DWG BY: AH

TITLE: **AUDW-330-12P**

SCALE: 1:24

DESCRIPTION: ABOVE GROUND, DOUBLE WALL  
12 GA. INNER/12 GA. OUTER  
STEEL STORAGE TANK

CAPACITY:

322 GALLONS

FINISH: SURFACE PREP: SPCC SP-3; ONE  
SPRAY COAT OF PRIMER; OPT FINISH  
APPROX. WEIGHT: 650 lbs ± 5%



Underwriters  
Laboratories Inc.  
LISTED ®

LEGEND: ID - (QTY. OF OPENINGS) PART

A - (4) 2" NPT CPL                      D - (1) 2" INSPECTION PIPE  
B - (1) 3" INNER E.VENT CPL        E - (1) LIFTING LUG  
C - (1) 3" OUTER E.VENT FLANGE



1500 HWY 117 S.  
GOLDSBORO, NC 27530  
P: (919) 734 - 8328  
F: (919) 736 - 4550

SIGNED APPROVAL: