



REF. TO: STANDARD TANK
DATE: 05/20/08

DWG BY: AH

TITLE: SKDW-1000/64-10P

SCALE: 1:24

DESCRIPTION: ABOVE GROUND, DOUBLE WALL
10 GA. INNER/12 GA. OUTER
STEEL STORAGE TANK ON SKIDS

FINISH: SURFACE PREP: SPCC SP-3; ONE
SPRAY COAT OF PRIMER; OPT FINISH
APPROX. WEIGHT: 1715 lbs ± 5%

CAPACITY:

1500 HWY 117 S.
GOLDSBORO, NC 27530
P: (919) 734 - 8328
F: (919) 736 - 4550

SIGNED APPROVAL:



Underwriters
Laboratories Inc.
LISTED ®

LEGEND: ID - (QTY. OF OPENINGS) PART

A-(3) 2" NPT CPL
B-(1) 6" INNER E.VENT CPL
C-(1) 6" OUTER E.VENT FLANGE
D-(1) 4" NPT CPL
E-(1) 2" INSPECTION PIPE
F-(3) FORGED LIFTING LUG

