



DESCRIPTION:	ABOVE GROUND, DOUBLE WALL, STEEL STORAGE TANK 4000 GALLONS	REF. TO:	
MATERIAL:	7 GA. INNER/10 GA. OUTER	DATE:	
CONSTRUCTION:	WELDED USING UL-142 STANDARDS	TITLE:	ASDW-4000-7P
OPENINGS:	3-2" CPL 1-4" CPL 1-8" INNER EVENT CPL 1-8" OUTER EVENT FLANGE	SIZE	LEGEND:
FINISH:	SURFACE PREP: SPCC SP-3 ONE SPRAY COAT OF RED PRIMER	A	A - 2" FLANGE B - 8" INNER EVENT CPL C - 8" OUTER EVENT FLANGE
TURNER TANKS: GOLDSBORO, NC (919) 734 - 8328		D	D - EXTRA 4" CPL
		E	E - 2" INSPECTION PIPE
		F	F - FORGED LIFT LUG
		SCALE: 1:96	APPROVAL: