



DESCRIPTION:	ABOVE GROUND, DOUBLE WALL, STEEL STORAGE TANK 3000 GALLONS	REF. TO:	
MATERIAL:	7 GA. INNER/10 GA. OUTER	DATE:	
CONSTRUCTION:	WELDED USING UL-142 STANDARDS	TITLE:	SKDW-3000-7P
OPENINGS:	3-2" FNPT CPL 1-4" FNPT CPL 1-6" INNER EVENT CPL 1-6" OUTER EVENT FLANGE	SIZE	
FINISH:	SURFACE PREP: SPCC SP-3 ONE SPRAY COAT OF RED PRIMER	A	A - 2" FLANGE B - 6" INNER EVENT CPL C - 6" OUTER EVENT FLANGE
TURNER TANKS: GOLDSBORO, NC (919) 734 - 8328		SCALE: 1:40	APPROVAL:
			D - EXTRA 4" CPL E - 2" INSPECTION PIPE F - FORGED LIFT LUG